



DET NORSKE VERITAS

TYPE APPROVAL CERTIFICATE

CERTIFICATE NO. E-8360
This Certificate consists of 4 pages

This is to certify that the
Low Voltage Cable
with type designation(s)
RU (i) & (c) 250 V


Holder of certificate
Draka Marine, Oil & Gas International
Houston, TX 77032, United States

is found to comply with
Det Norske Veritas' Rules for Classification of Ships, High Speed & Light Craft and Det Norske Veritas' Offshore Standards
IEC 60092-376 (2003-05)
IEC 60332-3-22 (2000-10)
IEC 60754-1 (1994-01)
IEC 60754-2 (1997-04)
IEC 61034-2 (2005-04)
NEK 606 (2004)

Application
Control. General power and lighting. Halogen free. Low smoke.

Voltage class (V)	250
Temp. class (°C)	90

Place and date
Høvik, 2007-05-11
for DET NORSKE VERITAS AS


Frode Berntsen
Head of Section



Local Office
DNV Oslo

This Certificate is valid until
2011-06-30


Ivar Bull
Surveyor 

Notice: This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

If any person suffers loss or damage which is proved to have been caused by any negligent act or omission of Det Norske Veritas, then Det Norske Veritas shall pay compensation to such person for his proved direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question, provided that the maximum compensation shall never exceed USD 2 million. In this provision "Det Norske Veritas" shall mean the Foundation Det Norske Veritas as well as all its subsidiaries, directors, officers, employees, agents and any other acting on behalf of Det Norske Veritas.



Cert. No.: E-8360
File No.: 827.20

Name and place of manufacturer:

Draka Norsk Kabel AS
Drammen, Norway

Product description

Type: RU (i) & (c) 250 V

Construction:

Conductors: Tinned, stranded copper

Core insulation: EPR

Sheath: SHF 2

Number of cores x conductor cross-section	Overall diameter	Overall diameter
	Collective screen	Individual screen
	mm ²	mm
		mm
1 x 2 x 0,75		8,5 ± 0,8
2 x 2 x 0,75	12,0 ± 1,0	12,0 ± 1,0
4 x 2 x 0,75	14,0 ± 1,0	13,5 ± 1,0
7 x 2 x 0,75	17,0 ± 1,0	16,5 ± 1,0
8 x 2 x 0,75	19,5 ± 1,0	19,0 ± 1,0
12 x 2 x 0,75	22,0 ± 1,5	21,5 ± 1,5
16 x 2 x 0,75	24,0 ± 1,5	24,5 ± 1,5
19 x 2 x 0,75	25,5 ± 1,5	26,0 ± 1,5
24 x 2 x 0,75	29,5 ± 1,5	30,5 ± 2,0
32 x 2 x 0,75	32,5 ± 2,0	34,0 ± 2,0
1 x 2 x 1,0		9,0 ± 0,8
2 x 2 x 1,0	13,0 ± 1,0	12,5 ± 1,0
4 x 2 x 1,0	15,0 ± 1,0	15,0 ± 1,0
7 x 2 x 1,0	18,0 ± 1,0	18,0 ± 1,0
8 x 2 x 1,0	20,5 ± 1,5	21,0 ± 1,5
12 x 2 x 1,0	23,5 ± 1,5	24,5 ± 1,5
16 x 2 x 1,0	25,5 ± 1,5	27,5 ± 1,5
19 x 2 x 1,0	27,0 ± 1,5	28,5 ± 1,5
24 x 2 x 1,0	31,0 ± 2,0	34,0 ± 2,0
32 x 2 x 1,0	34,5 ± 2,0	37,5 ± 2,0

Number of cores x conductor cross-section	Overall diameter	Overall diameter
	Collective screen	Individual screen
	mm ²	mm
		mm
1 x 2 x 1,5		10,0 ± 1,0
2 x 2 x 1,5	13,5 ± 1,0	13,5 ± 1,0
4 x 2 x 1,5	16,0 ± 1,0	16,0 ± 1,0
7 x 2 x 1,5	19,0 ± 1,0	20,0 ± 1,5
8 x 2 x 1,5	21,5 ± 1,5	22,5 ± 1,5
12 x 2 x 1,5	24,5 ± 1,5	26,5 ± 1,5
16 x 2 x 1,5	27,5 ± 1,5	30,0 ± 2,0
19 x 2 x 1,5	28,5 ± 1,5	31,5 ± 2,0
24 x 2 x 1,5	33,0 ± 2,0	37,0 ± 2,0
32 x 2 x 1,5	36,5 ± 2,0	41,0 ± 2,5
1 x 3 x 0,75		9,0 ± 0,8
2 x 3 x 0,75	13,5 ± 1,0	13,0 ± 1,0
4 x 3 x 0,75	16,0 ± 1,0	15,5 ± 1,0
7 x 3 x 0,75	19,0 ± 1,0	18,5 ± 1,0
8 x 3 x 0,75	21,5 ± 1,5	21,0 ± 1,5
12 x 3 x 0,75	24,5 ± 1,5	25,0 ± 1,5
16 x 3 x 0,75	27,0 ± 1,5	28,5 ± 1,5
19 x 3 x 0,75	28,5 ± 1,5	30,0 ± 2,0
24 x 3 x 0,75	33,0 ± 2,0	35,0 ± 2,0



Cert. No.: E-8360
File No.: 827.20

Number of cores x conductor cross-section	Overall diameter	
	Collective screen	Individual screen
	mm	mm
mm ²		
32 x 3 x 0,75	36,5 ± 2,0	38,5 ± 2,0
1 x 3 x 1,0		9,5 ± 0,8
2 x 3 x 1,0	14,0 ± 1,0	14,0 ± 1,0
4 x 3 x 1,0	16,5 ± 1,0	16,5 ± 1,0
7 x 3 x 1,0	20,0 ± 1,5	20,0 ± 1,5
8 x 3 x 1,0	22,0 ± 1,5	22,5 ± 1,5
12 x 3 x 1,0	26,0 ± 1,5	27,0 ± 1,5
16 x 3 x 1,0	28,5 ± 1,5	30,0 ± 2,0
19 x 3 x 1,0	30,0 ± 2,0	31,5 ± 2,0
24 x 3 x 1,0	35,0 ± 2,0	37,0 ± 2,0
32 x 3 x 1,0	39,0 ± 2,0	41,0 ± 2,5

Number of cores x conductor cross-section	Overall diameter	
	Collective screen	Individual screen
	mm	mm
mm ²		
1 x 3 x 1,5		10,5 ± 1,0
2 x 3 x 1,5	15,5 ± 1,0	15,5 ± 1,0
4 x 3 x 1,5	18,0 ± 1,0	18,5 ± 1,0
7 x 3 x 1,5	21,5 ± 1,5	22,5 ± 1,5
8 x 3 x 1,5	24,5 ± 1,5	25,0 ± 1,5
12 x 3 x 1,5	28,5 ± 1,5	30,0 ± 2,0
16 x 3 x 1,5	31,0 ± 2,0	34,0 ± 2,0
19 x 3 x 1,5	32,5 ± 2,0	35,5 ± 2,0
24 x 3 x 1,5	38,0 ± 2,0	42,0 ± 2,5
32 x 3 x 1,5	42,0 ± 2,5	46,5 ± 2,5

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Data sheets

- Letter SET/1b, dated 15.09.88, from EB NORSK KABEL
- Application Form No. 77.2a dated 13.9.88
- Test Report covering tests according to IEC 332-3 category A, dated 20.10.87

Tests carried out

Type tested according to:

Standard cable: IEC 60092-376, IEC 60332-3-22, IEC 60754-1/2 and IEC 61034-1/2.

On special request: Cold bend (-40 °C)/impact (-35 °C) test: CSA C 22.2 No 0.3-M1985.



Cert. No.: E-8360
File No.: 827.20

Marking of product

To be marked: DRAKA NORSK KABEL or DRAKA 01 - RU (i) or (c) - size - 250 V.

Certificate retention survey

The scope of the retention/renewal survey is to verify that the conditions stipulated for the Type approval is complied with and that no alterations are made to the product design or choice of materials.

The main elements of the survey are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Production Sample Tests (PST) and Routines (RT) checked (if not available tests according to PST and RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Survey to be performed at least every second year.

END OF CERTIFICATE