



DET NORSKE VERITAS

TYPE APPROVAL CERTIFICATE

CERTIFICATE NO. E-8395
This Certificate consists of 3 pages

This is to certify that the
Switchboard wires
with type designation(s)
UX P15 0,6/1 kV


Holder of certificate
Draka Marine, Oil & Gas International
Houston, TX 77032, United States

is found to comply with
Det Norske Veritas' Rules for Classification of Ships, High Speed & Light Craft and Det Norske Veritas' Offshore Standards
IEC 60092-353 (2001-04)
IEC 60332-3-22 (2000-10)
IEC 60754-1 (1994-01)
IEC 60754-2 (1997-04)
IEC 61034-2 (2005-04)
NEK 606 (2004)

Application
Switchboard wires. Halogen free.

Voltage class (kV)	0,6/1
Temp. class (°C)	90

Place and date
Høvik, 2007-05-11
for DET NORSKE VERITAS AS


Frode Berntsen
Head of Section



Local Office
DNV Oslo

This Certificate is valid until
2011-06-30


Ivar Bull
Surveyor 

Notice: This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

If any person suffers loss or damage which is proved to have been caused by any negligent act or omission of Det Norske Veritas, then Det Norske Veritas shall pay compensation to such person for his proved direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question, provided that the maximum compensation shall never exceed USD 2 million. In this provision "Det Norske Veritas" shall mean the Foundation Det Norske Veritas as well as all its subsidiaries, directors, officers, employees, agents and any other acting on behalf of Det Norske Veritas.



Cert. No.: E-8395
File No.: 827.10

Name and place of manufacturer:

Draka Norsk Kabel AS
Drammen, Norway

Product description

Type: UX P15 0,6/1 kV

Conductors: Plain or tinned, stranded copper Class 2 or 5
Core insulation: HF 90

Number of cores x conductor cross-section mm ²	Overall diameter mm
1 x 6	5,5±0,8
1 x 10	6,5±0,8
1 x 16	7,5±0,8
1 x 25	9,5±0,8
1 x 35	10,5±1,0
1 x 50	12,5±1,0
1 x 70	14,5±1,0

Number of cores x conductor cross-section mm ²	Overall diameter mm
1 x 95	16,5±1,0
1 x 120	18,0±1,0
1 x 150	20,0±1,5
1 x 185	22,0±1,5
1 x 240	25,0±1,5
1 x 300	28,0±1,5

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Data sheets: Draka UX_1000V.e00.doc
Test reports

Tests carried out

Type Tests according to:

Standard cables: IEC 60092-353, IEC 60332-3-22, IEC 60754-1/2 and IEC 61034-1/2

On special request: Cold bend (-40 °C)/impact (-35 °C) test: CSA C 22.2 No 0.3-M1985



Cert. No.: E-8395
File No.: 827.10

Marking of product

Product marking: DRAKA NORSK KABEL or DRAKA 01 – UX P15 – size - 0,6/1 kV

Certificate retention survey

The scope of the retention/renewal survey is to verify that the conditions stipulated for the Type approval is complied with and that no alterations are made to the product design or choice of materials.

The main elements of the survey are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Production Sample Tests (PST) and Routines (RT) checked (if not available tests according to PST and RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Survey to be performed at least every second year.

END OF CERTIFICATE