



# DET NORSKE VERITAS

## TYPE APPROVAL CERTIFICATE

**CERTIFICATE NO. E-8377**  
This Certificate consists of 3 pages

*This is to certify that the*  
**Low Voltage Cable**  
*with type designation(s)*  
**TXOI (c) & (i) 250 V**

*Holder of certificate*  
**Draka Marine, Oil & Gas International**  
Houston, TX 77032, United States


*is found to comply with*  
Det Norske Veritas' Rules for Classification of Ships, High Speed & Light Craft and Det Norske Veritas' Offshore Standards

IEC 60092-3  
IEC 60332-3-22 (2000-10)  
IEC 60754-1 (1994-01)  
IEC 60754-2 (1997-04)  
IEC 61034-2 (2005-04)

*Application*  
Control. Instrumentation and communication. Flame retardant. Halogen free. Low smoke.

Voltage class (V)	250
Temp. class (°C)	90

*Place and date*  
Høvik, 2007-05-11  
for DET NORSKE VERITAS AS

  
Frode Berntsen  
Head of Section



*Local Office*  
DNV Oslo

*This Certificate is valid until*  
2011-06-30

  
Ivar Bull  
Surveyor

**Notice: This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.**

If any person suffers loss or damage which is proved to have been caused by any negligent act or omission of Det Norske Veritas, then Det Norske Veritas shall pay compensation to such person for his proved direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question, provided that the maximum compensation shall never exceed USD 2 million. In this provision "Det Norske Veritas" shall mean the Foundation Det Norske Veritas as well as all its subsidiaries, directors, officers, employees, agents and any other acting on behalf of Det Norske Veritas.



Cert. No.: E-8377  
File No.: 827.20

### Name and place of manufacturer:

Draka Norsk Kabel AS  
Drammen, Norway

### Product description

Type: TXOI (c) or (i) 250 V

Conductors: Stranded copper

Core insulation: XLPE

Screen: Al/PETP-tape w/tinned drain wire. Common (c), Individual (i)

Inner covering: Tape (PETP)

Metal covering: Copper wire braid

Outer sheath: SHF1

Number of cores x conductor cross-section mm <sup>2</sup>	Overall diameter (c)	Overall diameter (i)
	mm	mm
1 pair 0,75	8,0±0,5	8,0±0,5
2 pairs 0,75	9,5±0,5	13,0±0,8
4 pairs 0,75	14,5±0,8	15,5±0,8
7 pairs 0,75	17,5±0,8	18,5±0,8
10 pairs 0,75	21,5±1,0	23,0±1,0

Number of cores x conductor cross-section mm <sup>2</sup>	Overall diameter (c)	Overall diameter (i)
	mm	mm
14 pairs 0,75	23,5±1,0	25,5±1,0
19 pairs 0,75	26,0±1,0	28,0±1,0
24 pairs 0,75	29,5±1,0	33,0±1,5

### Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

### Type Approval documentation

Test reports  
Data sheets

### Test carried out

Type tests according to IEC 60092-3, IEC 60332-3-22, IEC 60754-1/2 and IEC 61034-1/2.



Cert. No.: E-8377  
File No.: 827.20

### **Marking of product**

Product marking: DRAKA NORSK KABEL or DRAKA 01 - TXOI (c) or (i) - 250 V – Size

### **Certificate retention/renewal survey**

The scope of the retention/renewal survey is to verify that the conditions stipulated for the Type approval is complied with and that no alterations are made to the product design or choice of materials.

The main elements of the survey are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Production Sample Tests (PST) and Routine Tests (RT) checked (if not available tests according to PST and RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Survey to be performed at least every second year.

END OF CERTIFICATE